

Dylan Minek

From: Greg Hebble <greg@elyriafence.com>
Sent: Friday, September 26, 2025 3:07 PM
To: Dylan Minek
Subject: Rego's Fence, 19986 Beachcliff Blvd

Caution! This message was sent from outside your organization. Do not open attachments or click links from unknown senders!

[Allow sender](#) | [Block sender](#)

Dear Dylan,

Thank you for your e-mail. My calculations are that it is 50% open to light and air passage. The calculation is based on 1.5" lattice strips with a 1.5" of space in between each strip.

Thank you again.

Sincerely,

Greg Hebble

Elyria Fence Inc.

From: info <info@elyriafence.com>
Sent: Friday, September 26, 2025 2:11 PM
To: Kelly Stumphauzer <kelly@elyriafence.com>; Greg Hebble <greg@elyriafence.com>
Subject: FW: Rego's Fence, 19986 Beachcliff Blvd

From: Dylan Minek <dminek@rockyriverohio.gov>
Sent: Friday, September 26, 2025 11:18 AM
To: info <info@elyriafence.com>
Subject: Rego's Fence, 19986 Beachcliff Blvd

To whom this may concern,

I was wondering if you had a calculation on the transparency of the fence that is being proposed. Could you provide that documentation to me?

Thank you,

Dylan Minek

Planning and Community Development Administrator

City of Rocky River

dminek@rockyriverohio.gov

Office: 440-331-0600