Design and Construction Board of Review Meeting Minutes February 5, 2024

A meeting of the Design and Construction Board of Review was held at 5:00 PM at the Rocky River Senior Center, with the following members present:

Tom Evans, Member Steven Jennings, Member Kiera Szytec, Member

1. MAYOR PAMELA BOBST

Administer the Oath of Office to Kiera Szytec as a new member of the Design and Construction Board of Review

Mayor Bobst administered the Oath of Office to Kiera Szytec as a new member of the Design and Construction Board of Review and thanked the entire Board for their service to the Community. Ms. Szytec thanked Mayor Bobst and shared information about her experience.

2. **CITY OF ROCKY RIVER SENIOR CENTER** <u>FINAL REVIEW</u> 21014 Hilliard Blvd. <u>FINAL REVIEW</u> Senior Center Additions

Present: Timothy Wagner and Don Rerko, of MPA, General Contractors

- Rear material is EIFS to match existing siding and it was discussed and applicant agreed that they can look into providing a more thoughtfully placed pattern of control joints in application of the EIFS for symmetry and rhythm
- Prairie style architecture was introduced by the applicant as well as pictures of homes with this design
- Ms. Szyte does not mind the entry and tall geometry in front because she feels it provides a visible anchor and the existing entrance works well programmatically; she suggested use of a more durable material at grade rather than bring EIFS all the way down
- Stone on the right front façade was discussed and alternatives to lighten the mass of stone such as installing siding above the windows.
- Project budget may be too limited to accomplish many of the suggestions from the Board for this project; applicants will further review some of the suggestions with their clients.

Design and Construction Board of Review Meeting Minutes February 5, 2024

Mr. Jennings moved to grant final approval of the project and encouraged applicant to consider having variation in the material to break up the massiveness of the stone façade and providing more control joints in the EIFS panels. Mr. Evans seconded.

3 Ayes Passed

Project still requires Planning Commission final approval.

Respectful	lly submitted,	
Thomas E	vans, Chairman	
Steven Jer	nnings, Member	
IX. G	tec, Member	