

applicant confirmed moving its location to meet the 10-foot fire code requirement

Store Name/ #: E+H Ace Hardware #15450

Account #: 256204

Date of Site Plan: 7-14-2026

Installation Address: 20200 Detroit Rd.

City: Rocky River

State: OH Zip: 44116

STORAGE CABINET(S)

- ☐ Bolted Down
☐ NFPA 58 Clearance

No. of Cabinets: 2

Cabinet Size: 21 cab

Total Cylinders del: _____

VEHICLE PROTECTION

- ☐ Crash Posts

of post required _____

- ☐ 6 in. Curb

☐ Other: _____

DOORS INTO BUILDING

- ☐ One

- ☒ More Than One

Cabinet Distance: 5'6" ft. **10'**

FIRE EXTINGUISHER

Type: _____

Size: _____ lbs.

Cabinet Distance: _____ ft.

Store Manager Name: _____

Store Phone: _____

Distributor and Installer Name: _____

Blue Rhino Grove City, PA

Jack Nichols







